



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2009160
Permit # 00402-2016UPG
Request Rec'd 04/09/2016
Amended Date
Approval Date 4/12/2016 DS
Permit Expires 10/12/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Buchanan Energy N, LLC 4973 Dodge Street Omaha, NE 68132</p> <p>Contact: Nichole Mallett (402) 558-9860</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Bucky's Express #405 10 W. Dundee Road Buffalo Grove, IL 60090</p> <p>Contact: Nichole Mallett (402) 558-9860</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 6,000, (TK # 7, 8) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 6) - Diesel Fuel, (TK # 7, 8) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices: (TK # 6, 7, 8) Spill Contain Device - Manhole Pre-manufactured OPW 1C-2100C-PEVR*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

We will removing the existing Multi Port fills on the both RUL tanks and Diesel tanks.

We will remove teh Veeder Root Sump sensor in these sumps only and program out of sytem.

We will install new OPW 1C-2100C-PEVR grade level overfills with new swivel fill adapters. We will also replace the 4" tank risers. We will backfill old multiport sump area with pea stone.

Note: we will inspect and test existing ball floats on Stage 1 vapor and if they do not pass inspection we will then install new OPW


71SO overfill drop tubes

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Ray Kirchner
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File