



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2023961  
Permit # 00483-2016UPG  
Request Rec'd 04/29/2016  
Amended Date  
Approval Date 5/2/2016 DS  
Permit Expires 11/2/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>FedEx Ground Pkg. System, Inc. 1000 FedEx Drive Moon Township, PA 15108  Contact: Lori Nogrady (412) 747-8494</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>FedEx Ground 6833 W. 75th Street Bedford Park, IL 60638  Contact: Steve DiGrazia (708) 728-3760</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6, 7, 8) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6, 7, 8) Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping, (TK # 6, 7, 8) Piping - Shear Valves, (TK # 6, 7, 8) Piping - Valves Ball Valve, (TK # 6, 7, 8) Piping - Submersible Sumps XERXES Fiberglass, (TK # 6, 7, 8) Piping - Dispenser Sumps Bravo B-1000 Series, (TK # 6, 7, 8) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 6, 7, 8) - Diesel Fuel*
- (e) *Type of leak detection being used:*
  - Tank: (TK # 6, 7, 8) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus ATG*
  - Piping: (TK # 6, 7, 8) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Installing new Gilbarco Encore 500 with Def per drawing. New islands in the same location as the existing islands. The canopy is existing and will remain. All new piping as shown on drawing, new tank sumps and dispenser sumps. The existing tls 350 will be replaced with a tls 450 plus.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue

Contact Person: Rick Krol  
Phone: (708) 478-6190

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File