



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6041636  
Permit # 00486-2016UPG  
Request Rec'd 04/27/2016  
Amended Date  
Approval Date 5/2/2016 DS  
Permit Expires 11/2/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Midwest Petroleum Company 6760 Southwest Avenue Saint Louis, MO 63143</p> <p>Contact: Jeff Ziegler (314) 647-5550 Ext. 505</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>MPC #33 1291 Frank Scott Parkway West Belleville, IL 62223</p> <p>Contact: Erik D. Ilgenfritz (314) 647-5550</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC, (TK # 1, 2) Piping - Shear Valves, (TK # 1, 2) Piping - Valves Ball Valve, (TK # 1, 2) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series, (TK # 1, 2) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Attached scope of work indicates the replacement of an existing dispensing island. If the piping they have listed on equipment list is only to install partial to accomodate new sumps, then the sumps do not require sensors if not already existing as long as they do not replace more than 20' of piping or more than 50% of any piping run.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Parker Petroleum Sales and Service Inc.  
1424 South Main Street

Contact Person: Philip R Parker  
Phone: (636) 240-7777

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File