



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2007075  
Permit # 00492-2016UPG  
Request Rec'd 05/02/2016  
Amended Date  
Approval Date 5/2/2016 DS  
Permit Expires 11/2/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Speedway, LLC P.O. Box 1500 Springfield, OH 455011500</p> <p>Contact: Eric M. Swaisgood (937) 863-6513</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Speedway #5338 421 West Wise Road Schaumburg IL 60193</p> <p>Contact: Zyed Sufi (937) 863-6513</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 4, 5, 6) - 12,000, (TK # 7) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 4, 5, 6, 7) Piping - Galvanized Steel Single Wall Piping*

(d) *Product to be stored in each tank: (TK # 4, 5, 6) - Gasoline, (TK # 7) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Per OSFM NOV E0020161081 Dated 4/6/206

We will remove the dispensers that are related to the tanks under this violation and replace teh 1-1/2 Galvanized Steel risers to adjuste teh shear valves to proper height. All work is being done inside of sumps. After inspections we will reinstall existing dispensers back on islands and test


Note: We will clean sumberge sumps only. Cathodic Protection will have to be installed by others.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.  
600 East Joe Orr Road  
Chicago Heights, IL 60411

Contact Person: Ray Kirchner  
Phone: (708) 758-3222  
Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File