



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2007979
Permit # 00511-2016UPG
Request Rec'd 05/04/2016
Amended Date
Approval Date 5/4/2016 DS
Permit Expires 11/4/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|---|--|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>I-55 Truckstop Properties LLC 510 S. Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: John Puthusseril (630) 739-7006</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Greater Chicago Truck Plaza 510 South Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: Jeremy Smith (630) 739-7006</p> |
|---|--|

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 17) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 17) Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping, (TK # 17) Piping - Other submersible pump, (TK # 17) Piping - Fiberglass Secondary Containment Ameron*

(d) *Product to be stored in each tank: (TK # 17) - Bio-Diesel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 17) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D, (TK # 17) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 17) Spill Contain Device - Manhole Pre-manufactured OPW I-2100*

(h) *Overfill prevention devices: (TK # 17) Overfill Prev Device - Overfill Drop Tube Valve OPW 71-SO 4010 Overfill drop tube*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

We propose to add an additional FE Petro sub pump with a MLD-D line leak detector in the existing sump of the B-99 tank. We will install approx. 8' of Smith IIA pipe to a piping sump with a V/R #794380-208 piping sump sensor installed in this sump. Please see site drawing for details

There will be no other work done at this time.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Chris Epkins
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File