



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 7011186  
 Permit # 00539-2016UPG  
 Request Rec'd 05/09/2016  
 Amended Date  
 Approval Date 5/9/2016 DS  
 Permit Expires 5/20/2016

**Permit for Emergency Repair Request on 5/7/2016**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>A &amp; S Enterprises of Illinois, LLC        P.O. Box 221        Carmi, IL 62821</p> <p>Contact: Stacy Austin (812) 421-8890</p>	<p>(2) <b>FACILITY</b> - name and address where tanks are located:</p> <p>Pundrake, A &amp; S Enterprise of ILL, LLC        405 Fifth Street        Carmi, IL 62821</p> <p>Contact: Twila Bridges (812) 454-8924</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 4) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 4) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replacing broken shear valve that happened when dispenser was pulled over. NOTE: If there is not currently a sump under this dispenser, one MUST be installed per 175.410 d)

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Jorgensen Petroleum Maintenance, Inc.        921 Keck Avenue        Evansville, IN 47711</p>	<p>Contact Person: Matt Backer        Phone: (812) 424-0014        Contractor Registration # IL2145 Exp. 6/19/2017</p>

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File