



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2028438
Permit # 00605-2016UPG
Request Rec'd 05/17/2016
Amended Date
Approval Date 5/23/2016 DS
Permit Expires 11/23/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Schiller Park Marathon Inc 9754 Irving Park Rd Schiller Park, IL 60176</p> <p>Contact: Bhagat Ifan (847) 871-7887</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Schiller Park Marathon 9754 Irving Schiller Park, IL 60176</p> <p>Contact: Khaleq Shareef (847) 871-7887</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 4,000, (TK # 2, 3) - 6,000, (TK # 10) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3, 10) Piping - Fiberglass Single Wall Piping A.O. Smith , (TK # 1, 2, 3, 10) Piping - Shear Valves , (TK # 1, 2, 3, 10) Piping - Dispenser Sumps Franklin Fueling Systems 4800 Series*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel, (TK # 2, 3, 10) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : The gasoline dispenser island, not under the canopy, will be replaced to accommodate a containment sump addition at the same position. The existing single wall fiberglass diesel piping will be extended 20 lf. to the new sump and the existing single wall fiberglass gasoline pipe will be run back into the sump. **NOTE: Per 175.420 b), if replaced piping exceeds more than 20' OR more than 50% of the total piping run, the entire piping run must be replaced with double wall piping**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street	Contact Person: Ed Angell Phone: (708) 474-3344

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File