



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 4000073
Permit # 00618-2016UPG
Request Rec'd 05/25/2016
Amended Date
Approval Date 5/25/2016 DS
Permit Expires 11/27/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>C&O Equipment Company, Inc. 400 Northtown Road Normal, IL 61761 Contact: Kip McDowell (309) 452-8392</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Williams National Lease 300 Northtown Road Normal, IL 61761 Contact: Kip McDowell (309) 452-1110</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Flexible Double Wall OPW Flexworks CP-15 non corrosive*
- (d) Product to be stored in each tank: (TK # 2) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

We will install a new OPW CP-15 1 1/2" double wall line in the existing chase pipe from the tank to the existing dispenser sump.

We will install a new Incon TSP-ULS sump sensor in the existing dispenser sump, existing sensor to remain in the tank sump.

there will be no other permitted work done at this time.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Illinois Oil Marketing Equipment, Inc.

Contact Person: Chris Epkins

850 Brenkman Drive
Pekin, IL 61554

Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File