



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

<p align="center"><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 4000073 Permit # 00618-2016UPG Request Rec'd 05/25/2016 Amended Date 06/01/2016 Approval Date 5/25/2016 DS Permit Expires 11/27/2016</p>
---

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>C&amp;O Equipment Company, Inc. 400 Northtown Road Normal, IL 61761 Contact: Kip McDowell (309) 452-8392</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Williams National Lease 300 Northtown Road Normal, IL 61761 Contact: Kip McDowell (309) 452-1110</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 2) Piping - Flexible Double Wall OPW Flexworks CP-15 non corrosive*
- (d) Product to be stored in each tank: (TK # 2) - Diesel Fuel*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping: (TK # 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*


(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

There is not a chase for piping. We cannot pull a new flex pipe through. we will now replace piping with new LCX DW pipinf from tank sump to dispenser sump.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive</p>	<p>Contact Person: Chris Epkins Phone: (309) 347-1819</p>

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File