

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 2177851020

FOR OFFICE USE ONLY

Facility # 2046164 Permit # 00659-2016INS Request Rec'd 06/02/2016 Amended Date Approval Date 6/6/2016 DS Permit Expires 12/6/2016

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:

inity.

Speedway, LLC P.O. Box 1500

Springfield, OH 455011500

Contact: Eric M Swaisgood (937) 863-6513

(2) FACILITY - name and address where tanks are located:

Speedway #6809 2139 N Mannheim Road Northlake, IL 60164

Contact: Eric Swaisgood (937) 863-6513

(3) <u>INSTALLATION OF TANKS:</u>

- (a) Number and size of tanks being installed: (TK # 1, 5, 6, 7) 20,000, (TK # 2, 3) 6,000, (TK # 4) 12,000, (TK # 8) 10,000, (TK # 9) 550
- (b) Type of tank(s): (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9) Tank Fiberglass Double Wall Containment Solutions
- (c) Type of piping: (TK # 1, 2, 3, 4, 5, 6, 7) Piping Flexible Double Wall Franklin Fueling Systems UPP, (TK # 1, 2, 3, 4, 5, 6, 7, 8) Piping Submersible Sumps Containment Solutions Single Wall Fiberglass, (TK # 1, 2, 3, 4, 5, 6, 7) Piping Dispenser Sumps Franklin Fueling Systems UPP Dispenser sump, (TK # 8) Piping Steel Single Wall Piping OmegaFlex DEF-Trac flexible stainless steel with heat trace, (TK # 8) Piping Chase Secondary Containment OPW Geoduct non-corrosive flexible secondary piping, (TK # 9) Piping Single Wall Piping Buna Fernco connector bushing
- (d) Product to be stored in each tank: (TK # 1, 2) Gasoline, (TK # 3) E-85, (TK # 4, 5, 6, 7) Diesel Fuel, (TK # 8) Diesel Exhaust Fluid (Non-Regulated), (TK # 9) Oil/Water Separator
- (e) Type of leak detection being used:
 - Tank: (TK # 1, 2, 3, 4, 5, 6, 7, 8) Leak Detect Tank Automatic Tank Gauging Veeder Root TLS 450 Plus ATG, (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9) Leak Detect Tank Interstitial Monitoring Veeder Root TLS 450 Plus
 - Piping: (TK # 1, 2, 3, 4, 5, 6, 7) Leak Detect Piping Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 1, 2, 3, 4, 5, 6, 7, 8) Leak Detect Piping Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus, (TK # 5, 6, 7) Leak Detect Piping Siphon Bar, (TK # 9) Leak Detect Piping Gravity Feed
- (f) Corrosion Protection being used:

Tank: (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9) Corrosion Prot - Piping - Flexible Non-Corrosive

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 1, 2, 3, 4, 5, 6, 7) Spill Contain Device Manhole Premanufactured OPW 1C-3101DEVR 5 gallon, (TK # 8) Spill Contain Device Pre-manufactured Pomeco 211-RMOT remote fill spill containment, (TK # 9) Spill Contain Device Field Constructed
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4, 5, 6, 7) Overfill Prev Device Overfill Drop Tube Valve OPW 71SO-400C, (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9) Overfill Prev Device Overfill Alarm Veeder Root TLS 450plus
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.govor by calling (217)785-1020.

(5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) <u>SPECIAL CONTINGENCIES</u>:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Uni-Pump, Inc.

Contact Person: Steve Bennett

3070 Helsan Drive

Phone: (262) 674-1522

Richfield, WI 53076

Contractor Registration # IL1175 Exp. 6/8/2017

·

Sincerely,

Daniel Starks

Daniel J. Starke

cc: Storage Tank Safety Specialist Division File