



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

| |
|--|
| <p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 2033012 Permit # 00786-2016UPG Request Rec'd 06/28/2016 Amended Date Approval Date 6/28/2016 DS Permit Expires 12/28/2016</p> |
|--|

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>PACE Suburban Bus 550 West Algonquin Road Arlington Heights, IL 60005</p> <p>Contact: Dave Szaflauski (847) 228-4228</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Pace-Fox Valley Division 400 Overland Drive North Aurora, IL 60542</p> <p>Contact: Chris Rausch (630) 801-3006</p> |
|--|--|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Double Wall A.O. Smith , (TK # 1, 2, 3) Piping - Submersible Sumps XERXES Fiberglass, (TK # 1, 2, 3) Piping - Dispenser Sumps Bravo B-8000 Series*
- (d) Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel, (TK # 3) - Used Oil*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Manhole Pre-manufactured OPW 101-2100*
- (h) Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SO*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

DIESEL TANKS - INSTALL NEW OPW BG 101-2100 SPILL FILL, OPW 61SO SHUT OFF VALVE, REMOVE EXISITNG STP POLY SUMPS AND REPLACE WITH FRP SUMPS, REMOVE DISPENSER SUMPS AND REPLACE WITH BRAVO FRP DISPENSER SUMPS. MOVE VENTS FROM TOP OF TANK TO INSIDE THE NEW FRP SUMP.


WASTE OIL -NEW OPW BG101-2100 SPILL BUCKET WITH 61T DROP TUBE, INSTALL A WATER TIGHT LID ON THE EXISTING TANK SUMP,

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

K-Plus Mechanical, Inc.
329 W. 18th St., Ste. 614
Chicago, IL 60616

Contact Person: Gerald Ford
Phone: (815) 230-3040
Contractor Registration # IL002335 Exp. 2/9/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File