



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2015060
Permit # 00849-2016UPG
Request Rec'd 07/11/2016
Amended Date
Approval Date 7/12/2016 DS
Permit Expires 1/12/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Hartnett U Save Gas Stations, Inc. 1458 Bloomingdale Road Glendale Heights, IL 60139</p> <p>Contact: George Hartnett (312) 665-4370</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Minuteman Citgo 1458 Bloomingdale Road Glendale Heights, IL 60139</p> <p>Contact: Josh Caddick (312) 665-4370</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 8,000, (TK # 4, 5) - 6,000, (TK # 7) - 1,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3, 4, 5, 7) Piping - Shear Valves, (TK # 1) Piping - Submersible Sumps Bravo B-400 Series, (TK # 1) Piping - Flex Connector Steel, (TK # 5, 7) Piping - Dispenser Sumps Bravo B-1000 Series*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3, 4) - Gasoline, (TK # 5) - Diesel Fuel, (TK # 7) - Kerosene*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices: (TK # 5, 7) Overfill Prev Device - Overfill Drop Tube Valve Emco Wheaton A1100 Guardian*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Install a new tank sump on tank1, new dispenser sumps for Diesel and K1 dispensers as the shear valves are so low we have to cut the sump away to get to them. Raise all shear valves to the correct height. For all of the sumps we will match whatever piping is there now. The site shows it has both double wall and single wall pipe. Install new drop tubes on tanks 5 and 7. Islands for diesel and K1 will be replaced in the same locations as they are now. NOTE: Dispensers must have sumps installed after piping underneath is broken if no sump is existing per 175.410 d)

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Anderson Pump Service, Inc.

Contact Person: Ron Anderson

19659 South 97th Avenue
Mokena, IL 60448

Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 5/21/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File