



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2023145
Permit # 00879-2016UPG
Request Rec'd 07/06/2016
Amended Date
Approval Date 7/19/2016 DS
Permit Expires 1/19/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Kristensen Service Center, Inc. 230 Washington Street Woodstock, IL 60098</p> <p>Contact: Robert A. Kristensen (815) 338-0860</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Kristensen Service Center, Inc. 230 Washington Street Woodstock, IL 60098</p> <p>Contact: Robert A. Kristensen (815) 338-0860</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000, (TK # 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall A.P.T. Poly Tech PI50SC, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Dispenser Sumps Franklin Fueling Systems 3600 Series, (TK # 1, 2, 3) Piping - Submersible Sumps Franklin Fueling Systems 4200 Series double wall*
- (d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 1, 2, 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1, (TK # 1, 2, 3) Leak Detect - Piping - Stand Alone Sensor Interstitial Monitoring Veeder Root non discriminating
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Manhole Pre-manufactured EBW 705*
- (h) Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve EBW 705*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES : Stand alone sensors will be hard wired through a junction box in order to have the ability to shut down the STP upon detection of a release, per contractor

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Waltz Petroleum Service Inc.	Contact Person: Paul Kilde

5207 E. Jelenik Ave. Autank
Schofield, WI 54476

Phone: (715) 359-4362
Contractor Registration # IL1951 Exp. 4/10/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File