



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2038231
Permit # 00894-2016UPG
Request Rec'd 07/20/2016
Amended Date
Approval Date 7/20/2016 DS
Permit Expires 1/20/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Brouwer Brothers Steamatic 4120 West 123rd Street Alsip, IL 60803</p> <p>Contact: Charles Osborne (708) 396-1444</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Brouwer Brothers Steamatic 4120 West 123rd Street Alsip, IL 60803</p> <p>Contact: Charles Osborne (708) 396-1444</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Dispenser Sumps Franklin Fueling Systems 2400 Series*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Repairing leaking flex/shear valve under dispenser without required containment. Also installing required poly dispenser sump.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Ampco Service Corp 730 Creel Dr. Wood Dale, IL 60191</p>	<p>Contact Person: Chris Derro Phone: (708) 795-9052 Contractor Registration # IL002399 Exp. 12/20/2017</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File