



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2032041  
Permit # 00902-2016REM  
Request Rec'd 07/21/2016  
Amended Date  
Approval Date 7/21/2016 DS  
Permit Expires 1/23/2017

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>R &amp; D #4, Inc. 1491 W. Roosevelt Rd. West Chicago, IL 60185 Contact: (630) 479-1529</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>BP Am Pm Gas Station 350 Hunt Club Road Gurnee, IL 60031 Contact: Chirag Patel (847) 672-4450</p>
--	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 5) - 15,000, (TK # 6) - 20,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Remove existing dispensers, islands, product lines, and dispenser containment sumps.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Uni-Pump, Inc.  
3070 Helsan Drive  
Richfield, WI 53076

Contact Person: Steve Bennett  
Phone: (262) 674-1522  
Contractor Registration # IL1175 Exp. 6/8/2017

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File