



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2005733
Permit # 00806-2016UPG
Request Rec'd 07/05/2016
Amended Date 07/26/2016
Approval Date 7/5/2016 DS
Permit Expires 1/5/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Wilmette Auto Service, Inc. 1837 Wilmette Avenue Wilmette, IL 60091</p> <p>Contact: Mitch Klein (847) 251-6131</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Wilmette Auto Service, Inc. 1837 Wilmette Avenue Wilmette, IL 60091</p> <p>Contact: Mitchell Klein (847) 251-6131</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 8) - 10,000, (TK # 9) - 6,000, (TK # 10) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 8, 9, 10) Piping - Shear Valves, (TK # 8, 9, 10) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series*
- (d) Product to be stored in each tank: (TK # 8, 9) - Gasoline, (TK # 10) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

There has been a change in work plans. Now we will be doing the same work to all the dispenser pans instead of just one.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

BMPC, Inc.
1510 Spring Bay Road, Unit E
East Peoria, IL 61611

Contact Person: Amanda McCormick
Phone: (309) 208-5264
Contractor Registration # IL002393 Exp. 12/12/2016

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File