



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2040378  
Permit # 00935-2016UPG  
Request Rec'd 07/29/2016  
Amended Date  
Approval Date 8/1/2016 DS  
Permit Expires 2/1/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>CTJM One Real Estate, Inc. 7455 W. Archer Ave. Summit, IL 60501</p> <p>Contact: Cyriac K. Chandy (630) 673-3382</p>	<p>(2) <b>FACILITY</b> - name and address where tanks are located:</p> <p>Summit Citgo 7455 W. Archer Ave. Summit, IL 60501</p> <p>Contact: Jessica Garcia (630) 673-3382</p>
---	---

(3) **UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000, (TK # 2) - 12,000, (TK # 3) - 10,000, (TK # 4) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3, 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 1, 2, 3, 4) Piping - Shear Valves, (TK # 1, 2, 3, 4) Piping - Valves Ball Valve, (TK # 1, 2, 3, 4) Piping - Dispenser Sumps Bravo B-1000 Series, (TK # 1, 2, 3, 4) Piping - Submersible Sumps Bravo B-400 Series*
- (d) *Product to be stored in each tank: (TK # 1, 3) - Gasoline, (TK # 2) - Diesel Fuel, (TK # 4) - Kerosene*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping: (TK # 1, 2, 3, 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3, 4) Spill Contain Device - Manhole Pre-manufactured OPW 1C-2100C-DEVR*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES :**

- Removing existing (9) islands. Only the diesel island will be replaced to its former location. The (8) gasoline islands will be removed and replaced with (4) islands. Island size 3' x 5'.
- Removing existing fuel piping. Vent lines to remain.
- Reuse existing Veeder Root TLS 350.
- Reuse Existing Submersible pumps and mechanical line leak detectors.


- Reuse existing Tanks.
- Existing canopy to remain.
- Installing (4) new tank top piping sumps.
- Installing (5) new dispenser sumps.
- Installing new Veeder Root sump and dispenser sensors.
- Installing new Ameron Dualoy LCX piping from tank top sumps to island dispenser sumps.
- Installing new OPW 5 gallon overspill manholes.
- Concrete to be repaired when work is complete.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Crowne Industries, Ltd.  
651 S. Sutton Road #214  
Streamwood, IL 60107

Contact Person: Robert Sumoski  
Phone: (630) 497-9009  
Contractor Registration # IL002345 Exp. 5/16/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist  
Division File