



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2006663
Permit # 00962-2016UPG
Request Rec'd 07/26/2016
Amended Date
Approval Date 8/8/2016 DS
Permit Expires 2/8/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Lazar Enterprises, Inc. 15 North 454, Route 47 Pingree Grove, IL 60140 Contact: Lazar Joe (847) 683-2295</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Stark's Corner 15 N. 454, Rt. 47 Pingree Grove, IL 60140 Contact: Ephrem Lazar (847) 683-2295</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 21, 22) - 7,600*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 21, 22) Piping - Flexible Double Wall NUPI Smartflex, (TK # 21, 22) Piping - Dispenser Sumps NUPI HDPE*
- (d) Product to be stored in each tank: (TK # 21, 22) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 21, 22) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) SPECIAL CONTINGENCIES** : Installing/ extending DW Semi-Rigid Diesel piping from the existing Diesel dispenser / sump to (3) new Diesel dispenser sump / island locations under a new canopy as shown on plans. Each new dispenser sump will have VR single float liquid sensors installed. We will also be installing (1) new 3,000 gallon DWFRP (Xerxes) DEF tank with piping to (2) of (3) new dispenser islands.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 10/27/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File