



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2016791
Permit # 00985-2016REM
Request Rec'd 08/08/2016
Amended Date
Approval Date 8/9/2016 DS
Permit Expires 2/9/2017

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Co. 33978 N. US Hwy 45 Gages Lake, IL 600300089</p> <p>Contact: Joe Graham (847) 223-3710 Ext. 15</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Graham C-Stores Co. d/b/a Sugar Grove 201 North Route 47 42 West 400 Galena Boulevard Sugar Grove, IL 605549423</p> <p>Contact: Wendy Gustafson (847) 223-3710 Ext. 15</p>
--	---

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 4) - 10,000, (TK # 5) - 8,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 4, 5) - Diesel Fuel*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 4, 5) - 2/11/2016*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES** : Remove tanks #4 (10,000 gallon steel) and #5 (8,000 gallon steel) which have been condemned for tank lining failure. It was thought at first that the angle of repose for backfill on tank #4 would cause a danger to tank #3, but after uncovering tank #3 (to be upgraded under a separate permit), we now believe that these two tanks can be removed, and do not need to be abandoned in place.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 10/27/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File