



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-039399  
Permit # 00159-2010FLX  
Request Rec'd 02/16/2010  
Amended Date  
Approval Date 2/16/2010 JC  
Permit Expires 8/16/2010

**Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Thorntons, Inc. 10101 Linn Station Road, P.O. Box 34230 Louisville, KY 40223  Contact: Patty Leonhardt (800) 928-8022	<b>(2) FACILITY</b> - name and address where tanks are located:  Thornton Oil 5900 S. Harlem Ave. (SWC) Summit, Cook Co., IL  Contact: Gabriel Franco (708) 458-3227
--	--

**(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:**

- (a) Number and size of tanks being upgraded or repaired:** (TK # 1) - 20,000 gallons, (TK # 2, 3) - 12,000 gallons, (TK # 4, 5) - 6,000 gallons
- (b) Type of flex connector(s):**
- (c) Product stored in each tank:** (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel, (TK # 5) - Kerosene
- (d) Corrosion Protection being installed with flex connector(s):** (TK # 1, 2, 3, 4, 5) - (Installing) Sacrificial Anode Cathodic Protection at each submersible only (TK #1 has two submersible pumps).

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  US Tank Protectors, Inc. 5100 Walnut Avenue, Downers Grove, IL 60515	Contact Person: Phone:  Contractor Registration #    Exp.
---	--

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)