



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2021088
Permit # 01051-2016UPG
Request Rec'd 08/18/2016
Amended Date
Approval Date 8/18/2016 DS
Permit Expires 2/21/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141 Contact: Jamie Martinez (630) 379-8463	(2) <u>FACILITY</u> - name and address where tanks are located: True North Location 1915 9600 Crawford Skokie, IL 60076 Contact: Guss Dollyogiannis (330) 792-9999 Ext. 127
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6, 7) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 5, 6, 7) Piping - Valves Ball Valve, (TK # 5, 6, 7) Piping - Submersible Sumps Bravo B-400 Series, (TK # 5, 6, 7) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 5, 6, 7) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) SPECIAL CONTINGENCIES** : Replace tank sumps on all 3 tanks. Cut back piping for sump installation and extend it back into new sumps. Sensors will remain the same and be reused. No changes in site layout.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 5/21/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File