



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2035789
Permit # 01082-2016UPG
Request Rec'd 08/17/2016
Amended Date
Approval Date 8/24/2016 DS
Permit Expires 2/24/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Veer Petro, Inc. 300 Dixie Highway Chicago Heights, IL 60411 Contact: (708) 473-7140	(2) <u>FACILITY</u> - name and address where tanks are located: Veer Petro, Inc. 300 Dixie Highway Chicago Heights, IL 60411 Contact: Sukhdev Singh 7083339798
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 12,000, (TK # 7) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 6, 7) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 6) Piping - Chase Secondary Containment A.P.T. Poly Tech DCT-400, (TK # 6) Piping - Shear Valves, (TK # 6) Piping - Valves Ball Valve, (TK # 6, 7) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series, (TK # 6, 7) Piping - Submersible Sumps Franklin Fueling Systems 4542 Series Polyethylene, (TK # 6) Piping - Flex Connector Steel*

(d) *Product to be stored in each tank: (TK # 6, 7) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 6, 7) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD, (TK # 6, 7) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 interstitial piping float sensor in both tank sumps and all dispenser sumps, (TK # 6, 7) Leak Detect - Piping - Interstitial Monitoring

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Disconnecting premium line from tank #7. Connecting tanks #6 & #7 together with double wall ameron LCX product piping. Will make both tanks run regular unleaded. Rerouting vents to new location. Contractor is manifolding tanks 6 & 7 together

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

BMPC, Inc.
1510 Spring Bay Road, Unit E
East Peoria, IL 61611

Contact Person: Amanda McCormick
Phone: (309) 208-5264
Contractor Registration # IL002393 Exp. 12/12/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File