



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<p align="center"><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 4024443 Permit # 01094-2016UPG Request Rec'd 08/25/2016 Amended Date Approval Date 8/29/2016 DS Permit Expires 2/28/2017</p>
---

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>TA Operating LLC 24601 Center Ridge Road Suite 200 Westlake, OH 44145  Contact: Katie Wells (440) 808-3296</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>McLean Minit Mart #799 401 E. South McLean, IL 61754  Contact: Theresa Schertz (309) 874-2634</p>
--	---


- (3) UPGRADE OR REPAIR OF TANKS:**
- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4) - 8,000*
  - (b) Type of tanks:*
  - (c) Type of piping:*
  - (d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel*
  - (e) Type of leak detection being used:*
    - Tank: (TK # 1, 2, 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD*
    - Piping: (TK # 1, 2, 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIV, (TK # 4) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXID*
  - (f) Corrosion Protection being used:*
    - Tank:*
    - Piping:*
  - (g) Spill containment devices, piping, and dispenser containment devices:*
  - (h) Overfill prevention devices:*
  - (i) Manway accessible at grade:*
- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES :**
- Removing existing Incon TS1001 ATG and tank leak detection probes. Removing Incon line leak detectors.
  - Installing new Veeder Root TLS 450 Plus with CSLD, new Veeder Root Mag Plus leak detection probes, and Red Jacket FX1 series mechanical line leak detectors.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Pemco Service Company, Inc.</p>	<p>Contact Person: William "Butch" VonDrehle</p>
---	--

1040 East Second Street  
Gilman, IL 60938

Phone: (815) 265-7364  
Contractor Registration # IL1224 Exp. 2/23/2018

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File