



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2020554  
Permit # 01139-2016UPG  
Request Rec'd 09/11/2016  
Amended Date  
Approval Date 9/12/2016 DS  
Permit Expires 3/14/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Patten Industries, Inc. 635 W. Lake Street Elmhurst, IL 60126</p> <p>Contact: Terry Flick (608) 279-4400</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Patten Industries, Inc. 635 W. Lake Street Elmhurst, IL 60126</p> <p>Contact: Terry Flick (630) 279-4400</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 15) - 4,680, (TK # 16) - 930, (TK # 17, 19) - 2,340, (TK # 18) - 1,870, (TK # 20) - 932*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 15) - Diesel Fuel, (TK # 16, 18) - Transmission Oil, (TK # 17) - New Oil, (TK # 19) - Hydraulic Oil, (TK # 20) - Anti-Freeze*
- (e) *Type of leak detection being used:*
- Tank: (TK # 15, 16, 17, 18, 19, 20) Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel Integra 500*
- Piping: (TK # 15, 16, 17, 18, 19, 20) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring OPW Site Sentinel 1 single float*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

REPLACING EXISTING ATG SYSTEM WITH A NEW OPW INTEGRA 500 ATG SYSTEM FOR ALL ACTIVE TANKS


INTERSTITIAL MONITORING WITH OPW PIPING SUMP SENSORS

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Petroleum Technologies Equipment, Inc.  
8447 West 44th Place  
Lyons, IL 60534

Contact Person: Thomas J JR Doherty  
Phone: (708) 426-0400  
Contractor Registration # IL2051 Exp. 1/17/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File