



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453152

**FOR OFFICE USE ONLY**

Facility # 2037026  
Permit # 01150-2016UPG  
Request Rec'd 09/12/2016  
Amended Date  
Approval Date 9/13/2016  
Permit Expires 3/14/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Ozinga Chicago RMC, Inc. 19001 Old LaGrange Road, Suite 300 Mokena, IL 60448</p> <p>Contact: Rich Slager (708) 326-4210</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Ozinga Plant 2255 S Lumber St Chicago, IL 60616</p> <p>Contact: Matt Postema (312) 666-3310</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Flexible Double Wall OPW Flexworks CP-15 non corrosive, (TK # 1) Piping - Valves Ball Valve*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 1) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Pneumercator LS600LDBN*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Superior Petroleum Marketers, Inc.  
2336 Albright Lane P. O.Box 4648  
Wheaton, IL 601894648

Contact Person: Steve Tuttle  
Phone: (630) 588-1198  
Contractor Registration # IL2087 Exp. 2/4/2018

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File