



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 3014149
Permit # 01156-2016UPG
Request Rec'd 08/26/2016
Amended Date
Approval Date 9/14/2016 DS
Permit Expires 3/14/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>OSF Healthcare System 800 North East Glen Oak Avenue Peoria, IL 61603</p> <p>Contact: Michael Arnold (309) 655-2850</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>St. Francis Medical Center 530 North East Glen Oak Avenue Peoria, IL 61603</p> <p>Contact: Kevin Kemper (309) 655-2000</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000, (TK # 5) - 25,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 5) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX*
- (d) Product to be stored in each tank: (TK # 3, 5) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

The scope of work consists of the installation of (2) new supply lines from aboveground day tank inside of building to a new gen set and to the location of a future gen set, these lines are not regulated per a conversation with Fred Schneller on 8/4.


There will also be (2) new return lines, (1) from the location of both, the gen set and the future gen set to the existing tanks. The lines will be tee'd underground to be able to return to either tank. There will be solenoid valves in the tank sumps to prevent overfilling of the tanks. See site plan for layout. Existing VR PLLD and sump sensors to be re-used

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>
---

Illinois Oil Marketing Equipment, Inc.  
850 Brenkman Drive  
Pekin, IL 61554

Contact Person: Chris Epkins  
Phone: (309) 347-1819  
Contractor Registration # IL1293 Exp. 2/4/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File