



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2002500
Permit # 01180-2016UPG
Request Rec'd 09/19/2016
Amended Date
Approval Date 9/20/2016 DS
Permit Expires 3/21/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Village of Winnetka 510 Green Bay Road Winnetka, IL 60093</p> <p>Contact: Phil Soldano (847) 716-3633</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Village of Winnetka 1390 Willow Road Winnetka, IL 60093</p> <p>Contact: Phil Soldano (847) 716-3568</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2, 3) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2, 3) Piping - Fiberglass Double Wall A.O. Smith , (TK # 2, 3) Piping - Shear Valves , (TK # 2, 3) Piping - Valves none check valve*
- (d) *Product to be stored in each tank: (TK # 2, 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 2, 3) Leak Detect - Piping - European with No Test Req Suction*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Installing AO smith double wall pipe. The existing tank top sump will remain. Installing a small portion of pipe to accommodate the new island and dispenser pan. Installing an OPW 70 series check valve with shear groove under (2) dispensers.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File