



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2032510
Permit # 01254-2016ABN
Request Rec'd 09/29/2016
Amended Date
Approval Date 9/29/2016 DS
Permit Expires 3/29/2017

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: US DOT / FAA Chicago SMO 1100 Bowes Road Elgin, IL 60123 Contact: Weber David (842) 608-5814	(2) <u>FACILITY</u> - name and address where tanks are located: Dot/Faa Chicago Systems Mgr 1100 Bowes Road Elgin, IL 60123 Contact: John Welzenbach (842) 608-5814
--	---

(3) **ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned: (TK # 1) - 12,000, (TK # 3) - 600*
- (b) *Product stored in each tank: (TK # 1) - Diesel Fuel, (TK # 3) - Used Oil*
- (c) *Location of tanks being abandoned: Please view the attached Site Map and Picture showing the close location of the USTs in relation to Emergency Generator Radiators and the myriad of utilities around the USTs. Furthermore, the USTs are buried 6 feet deep so if we removed them the radiators would fall into the excavation.*
- (d) *Location of piping being abandoned: Please view the attached Site Map and Picture showing the close location of the USTs in relation to Emergency Generator Radiators and the myriad of utilities around the USTs. Furthermore, the USTs are buried 6 feet deep so if we removed them the radiators would fall into the excavation.*

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES :**

- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Chicago Tank Removal, Inc.
70 W. Madison St., Ste. 1400A
Chicago, IL 60602

Contact Person: David Streich
Phone: (312) 214-6144
Contractor Registration # IL002390 Exp. 7/17/2018

Sincerely,

Daniel Starks