



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2010730
Permit # 01264-2016LIN
Request Rec'd 10/01/2016
Amended Date
Approval Date 10/3/2016 DS
Permit Expires 4/4/2017

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Frank Mart, Inc. 9500 W. Grand Ave. Franklin Park, IL 60131 Contact: Mathew Milan (847) 691-6331	(2) <u>FACILITY</u> - name and address where tanks are located: Franklin Park Citgo 9500 West Grand Avenue Franklin Park, IL 60131 Contact: Deepa Nail (847) 916-2311
--	---

(3) INSPECTION OF INTERIOR LINING OF TANKS:

(a) *Number and size of tanks being inspected: (TK # 2) - 10,000*

(b) *Type of tank(s):*

(c) *Product stored in each tank: (TK # 2) - Gasoline*

(d) *Manway accessible at grade: (TK # 2) Existing*

- (4) Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading or interior lining is authorized with this permit.
- (5) The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (6) **SPECIAL CONTINGENCIES** : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Armor Shield of Wisconsin
4623 Hillcrest Parkway
Slinger, WI 53086

Contact Person: George Bennett
Phone: (262) 644-6447
Contractor Registration # IL1707 Exp. 4/18/2018

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File