



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6011107
Permit # 01266-2016UPG
Request Rec'd 09/28/2016
Amended Date
Approval Date 10/3/2016 DS
Permit Expires 4/4/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Moto, Inc. 721 W. Main St. P.O. Box 0122 Belleville, IL 62220122</p> <p>Contact: Rob Whittington (618) 233-6754 Ext. 106</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Red Bud Motomart 900 S. Main Street Red Bud, IL 62278</p> <p>Contact: Denise Metzger (618) 233-6754</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 4, 5, 6) - 10,000, (TK # 7) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4, 5, 6, 7) Piping - Flexible Double Wall OPW Flexworks, (TK # 4, 5, 6, 7) Piping - Chase Secondary Containment OPW AXP - 4" secondary chase piping, (TK # 4, 5, 6, 7) Piping - Shear Valves, (TK # 4, 5, 6, 7) Piping - Valves Ball Valve, (TK # 4, 5, 6, 7) Piping - Dispenser Sumps OPW FDS-4000 Series, (TK # 4, 5, 6, 7) Piping - Submersible Sumps OPW Fiberglass, (TK # 4, 5, 6, 7) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 4, 5, 6) - Gasoline, (TK # 7) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 4, 5, 6, 7) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS in dispenser sumps, sensors are existing in submersible sumps*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 4, 5, 6, 7) Spill Contain Device - Manhole Pre-manufactured OPW 1-2200 Spill Containment Manhole*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*


- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Remove the existing canopy, islands and piping. Install new canopy. Install dispenser sumps at grade level with 4" pipe bollards for crash protection. Install new OPW FlexWorks 2" piping with APX access pipe. Install new FRP tank sumps on tanks 5.6 & 7. The existing tank sump sensors to remain. The existing TS-LLD line leak detection to remain. New TS-ULS sump sensors to be installed in the new dispenser sumps.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
1458 Collins Street
St. Louis, MO 63102

Contact Person: Harvey Stokes
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File