



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2024605
Permit # 01269-2016UPG
Request Rec'd 10/04/2016
Amended Date
Approval Date 10/4/2016 DS
Permit Expires 4/4/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Schaumburg School District #54 524 East Schaumburg Road Schaumburg IL 60194</p> <p>Contact: Mike Mostacci (847) 357-6855</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Schaumburg School District 524 East Schaumburg Road Schaumburg IL 60194</p> <p>Contact: Mike Mostacci (847) 357-6855</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank: (TK # 2) Leak Detect - Tank - Automatic Tank Gauging Pneumercator LC1002 , (TK # 2) Leak Detect - Tank - Hydrostatic Reservoir Sensors Interstitial Monitoring Pneumercator RSU800 hydrostatic brine sensor*
 - Piping: (TK # 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Pneumercator LS600LDBN*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Existing Owens Corning Alarm Panel, Brine Sensor, and Tank Sump Sensor to be replaced with Pneumercator LC1002 Alarm Panel, LS600LDBN Tank Sump Sensor, & RSU800 Tank Interstitial Sensor.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Interstate Pump & Tank, Inc. 901 Niagara Street Waukesha, WI 53186</p>	<p>Contact Person: Dan McMahon Phone: (262) 524-8494 Contractor Registration # IL1171 Exp. 5/7/2018</p>

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File