



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2024590
Permit # 01274-2016UPG
Request Rec'd 10/05/2016
Amended Date
Approval Date 10/5/2016 DS
Permit Expires 4/5/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141</p> <p>Contact: Jamie Martinez (630) 379-8463</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>True North Location 1985 2212-50 Ogden Avenue Downers Grove, IL 60515</p> <p>Contact: Jay (330) 792-9999 Ext. 127</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall NUPI Smartflex, (TK # 1, 2, 3) Piping - Dispenser Sumps NUPI HDPE*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1, 2, 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 1, 2, 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : We will be removing the (2) farthest West dispensers / islands under the existing canopy. The existing C-Store under the existing canopy will be removed, and a new C-Store will be built where the existing carwash is located. The #2 Regular tank (Tank #3) will be converted to Diesel. The dispenser island layout will be revised so that there will be (2) additional islands (with Nupi HDPE dispenser sumps) where the C-Store was located along with the (2) existing dispenser / islands that were in fron of the old C-Store building. The SE & NE dispensers will be removed and replaced with 3+1 blenders with Diesel. The existing single sided blenders on the islands in front of the existing C-Store will be removed and replaced with the dispensers that were removed to facilitate the install of the 3+1 blenders with Diesel. The (2) dispensers removed from the farthest West islands will be installed at the (2) islands added where the old C-Store was located. The existing Nupi DW Semi-Rigid piping will be revised to facilitate these changes as shown on plan. We will be re-using the existing


VR liquid sensors in all the under dispenser sumps. Installing new 2" updraft vent cap on the Diesel tank, and installing Diesel float on the existing ATG probe. **NOTE: A removal permit is needed to remove Western piping run and dispenser sumps**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 10/27/2016

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File