



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2016439
Permit # 01277-2016UPG
Request Rec'd 10/05/2016
Amended Date
Approval Date 10/5/2016 DS
Permit Expires 4/5/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Thomas Chummar 2301 N. Highway 41, Unit A Gurnee, IL 60031 Contact: Jimmy Thomas (847) 769-5097	(2) <u>FACILITY</u> - name and address where tanks are located: Gurnee Truck Stop 2301 North Highway 41, Unit A Gurnee, IL 60031 Contact: Jimmy Thomas (847) 769-5097
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 7) Piping - Fiberglass Secondary Containment Ameron, (TK # 7) Piping - Shear Valves, (TK # 7) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series, (TK # 7) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 7) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

I have attached a copy of quote for project scope.

IPT to set (1) APT LMM-2010 Poly dispenser sump for satellite approx 15' north of northern most master diesel dispenser.

Doublewall Ameron LCX Duoloy pipe to be run.

A Veeder Root TLS-350 sump sensor will be installed for new sump.

Required OPW SS Flex Connecters will be placed at both ends of new pipe run with OPW # 10 Shear Valves.


Existing main trunk will remain. New line will be from meter outlet to new satellite dispenser.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Interstate Pump & Tank, Inc.
901 Niagara Street
Waukesha, WI 53186

Contact Person: Dan McMahon
Phone: (262) 524-8494
Contractor Registration # IL1171 Exp. 5/7/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File