



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4027656  
Permit # 01304-2016UPG  
Request Rec'd 10/10/2016  
Amended Date  
Approval Date 10/11/2016 DS  
Permit Expires 4/11/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>HPT PSC Properties, LLC 24601 Center Ridge Road Westlake, OH 44145  Contact: Jim Schenker (440) 808-7368</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Effingham Stopping Center 1805 W. Fayette Avenue Effingham, IL 62401  Contact: Susan Wright (217) 347-0443</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6) - 12,000, (TK # 8) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6, 8) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 5, 6, 8) Piping - Dispenser Sumps OPW DSW-1000 Series, (TK # 5, 6, 8) Piping - Submersible Sumps OPW Fiberglass*
- (d) Product to be stored in each tank: (TK # 5, 6) - Gasoline, (TK # 8) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 5, 6, 8) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 interstitial piping float sensor*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Gas island work only, all old product piping to be removed with removal permit. New product lines to be installed with dispenser sumps and submerge sumps added with sump sensors. Two new islands will be added to north end of canopy with canopy extended over new islands. Existing vent lines will be added on to enter new submerge pump sumps so that pump and vent lines are in new tank sumps.


**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: John B McKeighan

Petro Maintenance  
8766 E 1200th Ave. PO Box 194  
Robinson, IL 62454

Phone: (618) 544-7448  
Contractor Registration # IL725 Exp. 3/15/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File