



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2025605
Permit # 01328-2016UPG
Request Rec'd 10/13/2016
Amended Date
Approval Date 10/17/2016 DS
Permit Expires 4/18/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>PACE Suburban Bus 550 West Algonquin Road Arlington Heights, IL 60005</p> <p>Contact: Dave Szaflauski (847) 228-4228</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>PACE River Division 975 S. State, Route 31 Elgin, IL 60123</p> <p>Contact: Dave Slafarski (847) 228-2453</p>
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Valves Ball Valve, (TK # 1) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES** : Installing new Red Jacket BigFlo submersible pump. During this process a new ball valve and flex connector will be installed. NOTE: If there is no submersible sump existing one must be installed per 175.410 b)

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Accurate Tank Technologies, Inc.
204 Poplar Place
North Aurora, IL 60542

Contact Person: Steve Hirsch
Phone: (630) 375-6121 Ext. 10
Contractor Registration # IL1594 Exp. 8/15/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File