



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2018677
Permit # 01329-2016UPG
Request Rec'd 10/13/2016
Amended Date
Approval Date 10/17/2016 DS
Permit Expires 4/18/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Brookeridge Aero Associates, Inc. 437 Millbrook Drive Downers Grove, IL 60516 Contact: Robert Siegfried (630) 910-5286</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Brookeridge Aero Associates, Inc. 437 Millbrook Drive Downers Grove, IL 60516 Contact: John Egan (708) 560-5646</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 12,000, (TK # 3) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 2, 3) - Aviation Fuel*

(e) *Type of leak detection being used:*

*Tank: (TK # 2, 3) Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel iTouch , (TK # 2, 3) Leak Detect - Tank - Interstitial Monitoring OPW Site Sentinel I-Touch*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping: (TK # 2, 3) Corrosion Prot - Piping - Sacrificial Anode Flex Connector spike anode*

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Installing new OPWI-touch tank gauge with in tank probes and tank intersitial sensor for leak detection

Installing Sacrificial anodes on steel piping inside of existing tank top piping sumps

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Accurate Tank Technologies, Inc. 204 Poplar Place</p>	<p>Contact Person: Steve Hirsch Phone: (630) 375-6121 Ext. 10</p>

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File