



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2013288  
Permit # 01338-2016UPG  
Request Rec'd 10/13/2016  
Amended Date  
Approval Date 10/17/2016 DS  
Permit Expires 4/18/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>PACE Suburban Bus 550 West Algonquin Road Arlington Heights, IL 60005</p> <p>Contact: Dave Szaflauski (847) 228-4228</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Pace South Division 2101 W 163rd Place Markham, IL 60426</p> <p>Contact: Steve Angiollo (708) 225-3341</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Valves Ball Valve, (TK # 1) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


- (5) SPECIAL CONTINGENCIES** : Installing new Red Jacket BigFlo submersible pump. during this process a new ball valve and flex connector will be installed. NOTE: If there is not an existing sump one must be installed per 175.410 b)

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Accurate Tank Technologies, Inc.  
204 Poplar Place  
North Aurora, IL 60542

Contact Person: Steve Hirsch  
Phone: (630) 375-6121 Ext. 10  
Contractor Registration # IL1594 Exp. 8/15/2018

Sincerely,

---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File