



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2006940  
Permit # 01349-2016UPG  
Request Rec'd 10/18/2016  
Amended Date  
Approval Date 10/18/2016 DS  
Permit Expires 10/31/2016

**Permit for Emergency Repair Request on 10/18/2016**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Crown Properties Enterprise, Inc. 3553 W. 159th Street Markham, IL 60426</p> <p>Contact: Aqil Jaade (713) 791-1670</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Maple Petroleum 3553 W. 159th St. Markham, IL 60426</p> <p>Contact: Aqil Jaade (773) 791-1670</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7) Piping - Galvanized Steel Single Wall Piping , (TK # 7) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES** : A leaking steel riser pipe for the diesel product in dispenser sump #1/2 will be replaced along with the OPW, 10BF, shear valve. NOTE: If there is not an existing dispenser sump one MUST be installed under a separate upgrade permit per 175.410 d)

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: (708) 474-3344  
Contractor Registration # IL1207 Exp. 2/14/2018

Sincerely,

  

---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File