



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2006651
Permit # 01382-2016UPG
Request Rec'd 10/26/2016
Amended Date
Approval Date 10/26/2016 DS
Permit Expires 4/26/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Dean Dairy Holdings, LLC 6303 Maxon Road Harvard, IL 60033</p> <p>Contact: Charlie Vandebogart (815) 943-5441</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Dean Illinois Dairies, LLC 6303 Maxon Road Harvard, IL 600338854</p> <p>Contact: Wiz (Damian Wisowaty) (815) 943-5441</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 5) - Diesel Fuel

(e) Type of leak detection being used:

Tank: (TK # 5) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD , (TK # 5) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450

Piping: (TK # 5) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIDV , (TK # 5) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices:

(h) Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Alarm Veeder Root TLS 450


(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Installing new Veeder Root TLS-450 with CSLD, interstitial tank sensor, sump sensors and Veeder Root overfill alarm. Red Jacket mechanical line leak detector.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108</p>	<p>Contact Person: Nate Meyer Phone: (815) 398-6250 Contractor Registration # IL1890 Exp. 3/7/2018</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File