



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4025547
Permit # 01408-2016UPG
Request Rec'd 11/02/2016
Amended Date
Approval Date 11/2/2016 DS
Permit Expires 5/2/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company 3305 SE Delaware Avenue Ankeny, IA 50021</p> <p>Contact: Jill Reams-Widder (515) 965-6238</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Casey's General Store 203 East Main Colfax, IL 61728</p> <p>Contact: Kelli Castillo (515) 965-6238</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2) - 6,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 1, 2) Piping - Extractor Fitting Valves, (TK # 1, 2) Piping - Shear Valves, (TK # 1, 2) Piping - Valves Ball Valve, (TK # 1, 2) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series, (TK # 1, 2) Piping - Submersible Sumps Franklin Fueling Systems 4800 Series, (TK # 1, 2) Piping - Flex Connector Steel*

(d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline*

(e) *Type of leak detection being used:*

Tank: (TK # 1, 2) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

Piping: (TK # 1, 2) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 1, 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root Discriminating in all submersible and dispenser sumps

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Pre-manufactured EBW 705 CIGKT Defender spill containment*

(h) *Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Contractor installing new piping from existing sumps to dispensers

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Total Petroleum Service Company
2421 Washington Road
Washington, IL 61571

Contact Person: Greg R McCoy
Phone: (309) 694-8224
Contractor Registration # IL1079 Exp. 2/8/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File