



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2027432
Permit # 01415-2016UPG
Request Rec'd 11/02/2016
Amended Date
Approval Date 11/2/2016 DS
Permit Expires 5/2/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>OPW Fuel Management Systems, Inc. 6900 Santa Fe Drive Hodgkins, IL 60525</p> <p>Contact: Elizabeth Ivancsits (708) 387-8255</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>OPW Fuel Managements Systems, Inc. 6900 Santa Fe Drive Hodgkins, IL 60525</p> <p>Contact: Jerry Walsh (708) 485-4200 Ext. 4302</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 4,000

(b) Type of tanks:

(c) Type of piping: (TK # 1) Piping - Fiberglass Single Wall Piping Ameron , (TK # 1) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 1) Piping - Extractor Fitting Valves, (TK # 1) Piping - Dispenser Sumps OPW DP-1000 Series, (TK # 1) Piping - Flex Connector Steel

(d) Product to be stored in each tank: (TK # 1) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping: (TK # 1) Leak Detect - Piping - European with No Test Req Suction

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Scope of work includes

-Remove existing island

-Install new dispenser sump

-install new suction extractor at tank top


- Install new Ameron LCX product piping
- Install suction check valve under dispenser (piping to European suction)
- Install new single wall Ameron vent piping underground with steel galvanized vent riser
- Install new fueling island
- re-install existing dispenser

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Accurate Tank Construction
204 Poplar Place
North Aurora, IL 60542

Contact Person: Jason Reed
Phone: (630) 318-1813
Contractor Registration # IL002360 Exp. 8/28/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File