



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3034373
Permit # 01435-2016UPG
Request Rec'd 11/07/2016
Amended Date
Approval Date 11/7/2016 DS
Permit Expires 5/9/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>TA Operating LLC 24601 Center Ridge Road Suite 200 Westlake, OH 44145 Contact: Katie Wells (440) 808-3296</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Bartonville Minit Mart #613 2136 S. Airport Rd. Bartonville, IL 61607 Contact: Jeff Cruise (217) 732-2159</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2) - 6,000, (TK # 3) - 15,000, (TK # 5) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 1, 2) Piping - Transition Sumps OPW PSL-2000 Series, (TK # 1, 2, 3, 5) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1) - Diesel Fuel, (TK # 2) - E-85, (TK # 3, 5) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1, 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing islands for diesel and E-85 dispensers. Installing OPW PSL-2430 transition sumps in place of. Extending piping to adjacent dispenser sumps, (Ameron LCX double wall fiberglass). Installing V/R liquid sump sensors in both transition sumps and adjacent dispenser sumps.

Adding check valves, new ball valve and SS flex lines in existing STP sumps for tanks 3 and 5. Installing new dispensers and manifold tanks 3 and 5 under new dispensers above shear valve.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Pemco Service Company, Inc.
1040 East Second Street
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle
Phone: (815) 265-7364
Contractor Registration # IL1224 Exp. 2/23/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File