



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Revised

FOR OFFICE USE ONLY

Facility # 4014590
Permit # 01322-2016REM
Request Rec'd 10/13/2016
Amended Date
Approval Date 10/13/2016 SB
Permit Expires 4/13/2017

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: ABP Properties, LLC d/b/a ABP, LLC 1790 Nations Drive #213 Gurnee, IL 60031 Contact: Dr. Yogi Bhardwaj (312) 675-8774	(2) <u>FACILITY</u> - name and address where tanks are located: Marathon #7604 120 W. 1st Street Gibson City, IL 60936 Contact: (217) 784-5498
--	---

(3) REMOVAL OF TANKS:

(a) *Number and size of tanks being removed: (TK # 7) - 12,000, (TK # 8) - 10,000, (TK # 9) - 8,000, (TK # 10) - 560*

(b) *Description/location of piping being removed:*

(c) *Product to be stored in each tank: (TK # 7, 8, 9) - Gasoline, (TK # 10) - Heating Oil*

(d) *Reason of tanks being removed:*

(e) *If tank(s) is leaking, indicate IEMA incident number: 2016-0917*

(f) *Date each tank was last used: (TK # 7, 8, 9) - 4/1/2003, (TK # 10) - 4/1/2002*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest Petroleum Service, LLC
23535 North 1530 East Road
Danville, IL 61834

Contact Person: Mike Hall
Phone: (217) 443-2263
Contractor Registration # IL002306 Exp. 6/26/2018

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File