



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5025553
Permit # 01465-2016UPG
Request Rec'd 11/16/2016
Amended Date
Approval Date 11/16/2016 DS
Permit Expires 5/16/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Avenue Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	(2) <u>FACILITY</u> - name and address where tanks are located: Casey's General Stores Inc 620 South State Roodhouse, IL 62082 Contact: Jill Reams-Widder (515) 965-6100
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 1) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 1) Piping - Dispenser Sumps Franklin Fueling Systems 4200 Series single wall, (TK # 1) Piping - Submersible Sumps Franklin Fueling Systems A-4200 Series*
 - (d) Product to be stored in each tank: (TK # 1) - Gasoline*
 - (e) Type of leak detection being used:*
 - Tank: (TK # 1) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD*
 - Piping: (TK # 1) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root Pressurized, (TK # 1) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 interstitial piping float sensor*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1) Spill Contain Device - Pre-manufactured EBW 705 CIGKT Defender spill containment*
 - (h) Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : We are reinstalling all equipment that was installed on permit #01141-2016UPG and was later removed to allow the isolation of the tank for a precision tank test. Dispenser sumps were left in place.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive


Contact Person: Chris Epkins

Pekin, IL 61554

Phone: (309) 347-1819

Contractor Registration # IL1293 Exp. 2/4/2018

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File