



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2022908
Permit # 01472-2016UPG
Request Rec'd 11/18/2016
Amended Date
Approval Date 11/21/2016 DS
Permit Expires 5/23/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Graham C-Stores Co. 33978 N. US Hwy 45 Gages Lake, IL 600300089 Contact: Joe Graham (847) 223-3710 Ext. 15	(2) <u>FACILITY</u> - name and address where tanks are located: Elmhurst BP 1003 N. York Road Elmhurst, IL 60126 Contact: Linda Horstman (630) 833-2213
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 10, 12) - 10,000

(b) Type of tanks:

(c) Type of piping: (TK # 10, 12) Piping - Flexible Double Wall OPW Pisces

(d) Product to be stored in each tank: (TK # 10, 12) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Contractor is running a new manifold line between tanks 10 and 12 as shown in the site drawing. Tank 10 submersible will be the primary and tank 12 will be the slave tank with check valve. Both sumps have existing sensors.

Product piping from tank 12 submersible to islands will be capped at the submersible and under dispensers. An abandonment permit must be obtained in order to do this.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


DRW Services, Inc.

Contact Person: Ray Kirchner

600 East Joe Orr Road
Chicago Heights, IL 60411

Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File