



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 5040225
Permit # 01488-2016UPG
Request Rec'd 11/17/2016
Amended Date
Approval Date 11/22/2016 DS
Permit Expires 5/23/2017

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>M & M Service Company P.O. Box 500 Carlinville, IL 62626 Contact: David Wright (217) 854-4516</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Fast Stop Travel Center 4th Corvette Drive Litchfield, IL 62056 Contact: Peggy Lewis (217) 324-7114</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 3) - 6,000, (TK # 4) - 10,000

(b) Type of tanks:

(c) Type of piping: (TK # 3, 4) Piping - Valves OPW 99ASV-2200 Anti-siphon valve

(d) Product to be stored in each tank: (TK # 3, 4) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:


(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : We are going to disconnect one of the lines in the Mid Grade submerge pump sump going out to the dispensers and cap off the line, then we are going to pipe the midgrade tank to the unleaded tank using the dispenser sump by the Diesel island that is no longer being used. We are going to install inline back check valves in each submerge pump line for protection from a backfeed, we will then tie our E-85 product into the midgrade line under dispenser 3-4 so we can have E-85 at all the new dispensers once this is done we will have both lines hydrostatically tested for any leaks. The capped off line will remain monitored.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pemco Service Company, Inc. 1040 East Second Street	Contact Person: William "Butch" VonDrehle

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File