



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6044208  
Permit # 01493-2016UPG  
Request Rec'd 11/23/2016  
Amended Date  
Approval Date 11/23/2016 DS  
Permit Expires 5/23/2017

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Moto, Inc. 721 W. Main St. P.O. Box 0122 Belleville, IL 622220122  Contact: Rob Whittington (618) 233-6754 Ext. 106	<b>(2) FACILITY</b> - name and address where tanks are located:  Greenmount Motomart 1790 Frank Scott Parkway Shiloh, IL 62269  Contact: Jeff Zimmermann (618) 233-6756
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000*

*(b) Type of tanks:*

*(c) Type of piping:*

*(d) Product to be stored in each tank: (TK # 1) - Gasoline*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1) Spill Contain Device - Manhole Pre-manufactured OPW 1-2200 Spill Containment Manhole*

*(h) Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES** : Install new OPW spill containment manhole and OPW overfill valve on the South UL tank. The existing overfill valve will be re used if possible

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

UPC Enterprises, LC d/b/a United Petroleum Service  
1458 Collins Street  
St. Louis, MO 63102

Contact Person: Harvey Stokes  
Phone: (314) 241-3767  
Contractor Registration # IL002402 Exp. 2/10/2018

---

Sincerely,

*Daniel H. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File