

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 2177851020 FOR OFFICE USE ONLY

Facility # 2008503 Permit # 01523-2016ENT Request Rec'd 11/17/2016 Amended Date Approval Date 12/1/2016 DS Permit Expires 6/1/2017

Permit for HOTWORK / ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Julie's Car Wash, LLC 900 W. Euclid Arlington Heights, IL 60005	Northwest Auto Wash 900 W. Euclid Arlington Heights, IL 60005
Contact: Greg Kritz (847) 452-4485	Contact: Mark Olmsted (847) 259-1420

(3) ENTRY OF TANKS:

- (a) Number and size of tanks being entered: (TK # 5) 8,000
- (b) Type of tanks:
- (c) Product to be stored in each tank: (TK # 5) Gasoline
- (d) Reason for tanks being entered:
- (e) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling 2177851020.
- (5) <u>SPECIAL CONTINGENCIES</u>: Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. PUL tank taking on water, Containment Solutions to enter tank at end on upper dome to inspect tank, see what problem and repair if possiable.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc. 600 East Joe Orr Road Chicago Heights, IL 60411 Contact Person: Ray Kirchner Phone: (708) 758-3222 Contractor Registration # IL194 Exp. 3/10/2018

Sincerely,

Daniel J. Starke

Daniel Starks

cc: Storage Tank Safety Specialist Division File