



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

<p>FOR OFFICE USE ONLY</p> <p>Facility # 2032378 Permit # 01527-2016CAT Request Rec'd 11/23/2016 Amended Date Approval Date 12/2/2016 SB Permit Expires 6/2/2017</p>
--

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>G. F. Cornell Amoco 5048 South Cornell Street Chicago, IL 60615 Contact: Abdul R Ralput (773) 667-2901</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>G. F. Cornell Amoco 5048 South Cornell Street Chicago, IL 60615 Contact: Abdul R Ralput (630) 235-1947</p>
---	---

(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 4, 5) - 8,000, (TK # 7) - 550*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 4, 5) - Gasoline, (TK # 7) - Used Oil*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank: (TK # 4, 5, 7) Corrosion Prot - Tank - Impressed Current Cathodic Protection
 Piping:
- (g) *NACE certified designer:*
- (h) *Method of integrity assessment of tank(s) being used:*

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling 3127453152.

(5) SPECIAL CONTINGENCIES :

Splice new wires on the existing wires.
 Contractor cut wires. Need to reconnect for CP System on All Tanks

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, Inc.
 658 North Progress Drive PO Box 80265

Contact Person: Frank Grebas
 Phone: (262) 268-1150

Sincerely,

A handwritten signature in black ink that reads "Shelly Bradley". The signature is written in a cursive, slightly slanted style.

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File