



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 7-043788
Permit # 00311-2013UPG
Request Rec'd 04/18/2013
Amended Date
Approval Date 4/18/2013 JC
Permit Expires 10/18/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|---|--|
| (1) OWNER OF TANKS - Corporation, partnership, or other business entity: Russell Oil Company 200 E Main, PO Box 73 Galatia, IL 62935 Contact: Terry Stevens (618) 268-4722 | (2) FACILITY - name and address where tanks are located: ROC Convenience Store 1100 W. Broadway Johnston City, Williamson Co., IL Contact: Terry Stevens (618) 926-9180 |
|---|--|

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 2) - 5,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 2) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P175SC from the existing submersible sump to the existing first dispenser sump only (according to the contractor, there is an existing dispenser sump and an existing submersible sump). See overhead site plan. The remainder of the piping between the other dispensers will remain existing.

(d) Product to be stored in each tank: (TK # 2) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping: (TK # 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the submersible sump and at the first dispenser sump only.

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

| | |
|---|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: Cape Girardeau, MO 63703 | Contact Person: Billy Thorne Phone: (573) 335-5529 Contractor Registration # Exp. |
|---|---|

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)